




SECTION "A-A"



SECTION "B-B"



INSTALLATION OF LOW LEVEL BOX-UP PANEL AT CORNER ROOM



INSTALLATION OF LOW LEVEL BOX-UP PANEL AT MIDDLE ROOM

12mm INSULATION FOAM
25mm CLEARANCE (MIN.)

DUCT DROPPER
TDC JOINT INCLUDE CLIP
25mm CLEARANCE (MIN.)


25mm CLEARANCE (MIN.)

DUCT WIDTH + CLEARANCE + WALL THICKNESS


DUCT WIDTH + CLEARANCE

DUCT WIDTH + CLEARANCE + WALL THICKNESS


SECTION "C-C"



SECTION "D-D"



INSTALLATION OF LOW LEVEL BOX-UP PANEL AT CORNER ROOM




INSTALLATION OF LOW LEVEL BOX-UP PANEL AT MIDDLE ROOM


Technical drawing of a duct assembly showing dimensions and components:

- 12mm INSULATION FOAM
- 78mm CLEARANCE
- 400 x 250 DUCT CLIPPER
- TDC JOINT INCLUDE DOP
- 5.3mm CLEARANCE
- 30mm TDC JOINT
- 25.3mm CLEARANCE
- 80mm GAP
- 80mm GAP
- 450 (Ext.)
- 400 (Int.)
- 625 (Int.)
- 675 (Ext.)


SECTION "E-E"




INSTALLATION OF LOW LEVEL BOX-UP PANEL AT CORNER ROOM




SECTION "F-F"



INSTALLATION OF LOW LEVEL BOX-UP PANEL AT MIDDLE ROOM



SECTION "G-G"



DETAILS "A"